

# PLANNING AND TRANSPORTATION COMMITTEE REPORT

## Points to Note:

- There are 15 Public Lifts/Escalators in the City of London estate. The report below contains details of the three public escalator/lifts that were out of service less than 95% of the time.
- The report was created on 29<sup>th</sup> November 2018 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 07/11/2018	% of time in service Between 07/11/2018 and 04/12/2018	Number of times reported Between 07/11/2018 and 04/12/2018	Period of time Not in Use Between 07/11/2018 and 04/12/2018	Comments Where the service is less than 95%
<b>Millennium Inclinator SC6459245</b>	IN SERVICE	75.2%	2	131 Hours	16/11/2018 Entrapment. Engineer called to site and released trapped passengers within 30 minutes, however the engineer could not correct door fault on the lower doors. Technician returned the following day and identified parts required. Lift was fixed when parts had arrived and put back in service. 21/11/2018 Engineer attended site and found a fault with the upper doors, parts required. The technician returned the following day to repair and left lift in service.
<b>London Wall Down Escalator SC6458958</b>	IN SERVICE	65.9%	1	180 Hours	14/11/2018 – Escalator reported out of service due to faulty roller drive after an insurance inspection. Parts required with the engineer attending site on 22/11/2018, installed replacement parts and returned to service.
<b>Speed House SC6459146</b>	OUT OF SERVICE	64.0%	1	190 Hours	22/11/2018 – Drive Fault detected, technician attended and could not fix fault so left out of service. Technician returned to site the following day and repositioned lift but found water ingress to have entered main control panel, damaging drive board. Board has now been removed and sent away for repair, expected return to service date is the 7 <sup>th</sup> December 2018.