PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 15 Public Lifts/Escalators in the City of London estate. The report below contains details of the five public escalator/lifts that were out of service less than 95% of the time.
- The report was created on 01st February 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 01/02/2019	% of time in service Between 12/01/2019 and 01/02/2019	Number of times reported Between 12/01/2019 and 01/02/2019	Period of time Not in Use Between 12/01/2019 and 01/02/2019	Comments Where the service is less than 95%
Little Britain	IN SERVICE	91%	1	73 hours	12.01.19 – Lift car doors fault identified which required a Specialist technician, returned to site rectified problem and left lift in service
London Wall West Sc6458965	IN SERVICE	94%	1	34 hours	14.01.19 – Fault with lift was identified as a levelling fault, return visit the following day to repair and lift left in service.
London Wall Up Escalator SC6458959	IN SERVICE	90%	1	35 hours	12.01.19 – Engineer attended and found gear box leak which was causing the fault, parts required and returned to site the following day to repair and left the lift in service.
London Wall Down Escalator SC6458958	IN SERVICE	88%	1	120 hours	21.01.19 – COL engineer reported escalator fault due to a damaged comb plate. Parts required, engineer returned to site when they had arrived, repaired and left the escalator in service.

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Location	Status as of 01/02/2019	% of time in service Between 12/01/2019 and 01/02/2019	Number of times reported Between 12/01/2019 and 01/02/2019	Period of time Not in Use Between 12/01/2019 and 01/02/2019	Comments Where the service is less than 95%
Speed House SC6459146	Out of Service	0	0		Continued problems are being found each time one is resolved; the following parts have been replaced so far:

Additional information