

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the four public escalator/lifts that were in service for less than 95% of the time.
- The report was created on 28th February 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 28/02/2019	% of time in service Between 01/02/2019 and 27/02/2019	Number of times reported Between 01/02/2019 and 27/02/2019	Period of time Not in Use Between 01/02/2019 and 27/02/2019	Comments Where the service is less than 95%
London Wall West Sc6458965	IN SERVICE	74.3%	1	161 hrs	07/02/2019 – Lift entrapment - engineer attended within 30 minutes and released trapped passengers. Fault identified as lift stopping between floors caused by faulty safety gear, parts required, a return visit happened on the 14/02/2019 February when parts received. Lift repaired and left in service.
Speed House SC6459146	Out of Service	100%	0	624 hours	Lift was out of service for this reporting period due to a refurbishment project being undertaken. Expected return to service date is the 24 th June 2019. This lift will only be reported on subsequent reports if this timescale will not be met.
33 King William St SC6462850	IN SERVICE	42.9%	2	360 hours	02/02/2019 – Engineer attended site, lift was stuck between two floors it was reset and left in service. 08/02/2019 – Engineer attended site and found a fault with the Lift Drive mechanism. Parts required and a return visit on the 22/02/2019 was scheduled when parts received. Lift repaired and left in service.