

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the three public escalator/lifts where the service is less than 95%.
- The report was created on 11th April 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 15/03/2019	% of time in service Between 15/03/2019 and 11/04/2019	Number of times reported Between 15/03/2019 and 11/04/2019	Period Not in Use Between 15/03/2019 and 11/04/2019	Comments Where the service is less than 95%
Millennium Inclinor SC6459245	IN SERVICE	23%	2	499hrs	Out of Service until the 13/03/2019 due to damage sustained to lift car cable track. 25/03/2019 – Three-week project undertaken to replace key parts. Work concluded on the 12 th April when the Inclinor was put back in service.
London Wall West SC6458965	IN SERVICE	64.04%	1	233 hours	18/03/2019 - Intermittent fault, lift sensor indicating wrong direction of travel. Specialist Technician attended and identified parts required. Parts arrived on the 27/03/2019 when the lift was repaired and put back in service.
Atlantic House SC6458966	IN SERVICE	90%	5	59 hrs	15/03/2019 – Engineer attend site and found doors constantly opening and closing. Parts required and fault repaired when they arrived, lift left in service. However as this is a repeated fault the City's Lift engineer is to arrange a survey to investigate the root cause of the issue.

Additional information