

# PLANNING AND TRANSPORTATION COMMITTEE REPORT

## Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the five public escalator/lifts where the service is less than 95%.
- The report was created on 25th March 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

<b>Location</b>	<b>Status as of 28/02/2019</b>	<b>% of time in service Between 28/02/2019 and 14/03/2019</b>	<b>Number of times reported Between 28/02/2019 and 14/03/2019</b>	<b>Period of time Not in Use Between 28/02/2019 and 14/03/2019</b>	<b>Comments Where the service is less than 95%</b>
<b>Pilgrim St SC6458969</b>	IN SERVICE	35.5%	1	217 hrs	01/03/2019 – Engineer attended site, unable to access motor room due to homeless person sleeping in motor room doorway. Return visit when area cleared took place on the 05/03/2019. Engineer found a door fault, parts required, return visit on the 11/03/2019 when received. Lift repaired and left in service.
<b>Millennium Bridge SC6459245</b>	OUT OF SERVICE	64.0%	1	121 hrs	09/03/2019 – Engineer attended site and found the lift cable track damaged, parts required. These will now be added to the list of critical spares Lift still out of service at end of reporting period.
<b>London Wall West SC6458965</b>	IN SERVICE	87.2%	1	43 hours	09/03/2019 – Lift left out of service following entrapment. Specialist engineer required to rectify direction signal error. Return visit on the 11/03/2019 where the lift was repaired and left in service.
<b>Atlantic House SC6458966</b>	IN SERVICE	91.2%	2	30 hrs	04/03/2019 – Engineer attended site to accompany Skanska engineer to investigate sump pump fault. (1 hr) 13/03/2019 – Lift taken out of service due to failing outer doors where parts are required. Lift still out of service at end of reporting period. (29 hrs)

*Additional information*