

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the two public escalator/lifts where the service is less than 95%.
- The report was created on 03rd June 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 26/04/2019	% of time in service Between 26/04/2019 and 30/05/2019	Number of times reported Between 26/04/2019 and 30/05/2019	Period of time Not in Use Between 26/04/2019 and 30/05/2019	Comments Where the service is less than 95%
Atlantic House 2001 SC6458966	IN SERVICE	93.9%	3	56 hrs	20/05/2019 – Lift error fault, engineer reset lift and returned to service. 28/05/2019 – Lowest level door not closing fully, removed debris from car and landing cills, also removed smoke fillet on one side. Ran tested and left lift in service. 30/05/2019 – Doors not closing, repaired lift. Ran tested and left in service.
Millennium Bridge SC6459245	IN SERVICE	80.2%	4	156 hrs	04/05/2019 – Lift out of service due to faulty doors over bank holiday weekend, returned to service on the next working day. 07/05/2019 – Lift failing to move. Engineer attended site repaired fault and returned to service. 09/05/2019 – Lift out of service due to lift car door fault. 16/05/2019 – Upper level door out of alignment, engineer attended site, repaired fault and returned lift to service.

Additional information