

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the four public escalator/lifts where the service is less than 95%.
- The report was created on 16th July 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 16/07/2019	% of time in service Between 21/06/2019 and 16/07/2019	Number of times reported Between 21/06/2019 and 16/07/2019	Period of time Not in Use Between 21/06/2019 and 16/07/2019	Comments Where the service is less than 95%
Millennium Bridge SC6459245	IN SERVICE	80.18%	1	96 hrs	01/07/2019 - Control component causing fault, return visit by specialist technician required. Technician attended and repaired fault and ran tested and left lift in service.
Wood Street Public Lift SC6458970	IN SERVICE	71.55%	1	136 hrs	25/06/2019 – Lift not levelling at ground floor. Lift switched off awaiting specialist technician to complete repair. Technician returned to site, reprogrammed controller and left lift in service.
London Wall West SC6458965	IN SERVICE	33.20%	1	321 hrs	21/06/2019 – Lift out of service due to flood in lift pit and motor room. Engineer returned to site following removal of water, ran tested and left lift in service.
33 King William Street SC6462850	IN SERVICE	94.77%	1	26 hours	04/07/2019 – Engineer attended site found main power dropped out and was reinstated.

Additional information