

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 2 public escalator/lifts that were out of service for less than 95% of the time.
- The report was created on 08th October 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 13/09/2019	% of time in service Between 13/09/2019 and 08/10/2019	Number of times reported Between 13/09/2019 and 08/10/2019	Period of time Not in Use Between 13/09/2019 and 08/10/2019	Comments Where the service is less than 95%
Millennium Bridge SC6459245	OUT OF SERVICE	60.00%	1	216 hrs	1/10/19 – Door guide and door control panel damaged by water ingress. Parts required are not held as critical spares stock, this is the first time they have failed in 3 years. Specialist parts which have been ordered and have a lead time of 2 – 3 weeks. Lift still out of service at end of reporting period.
Blackfriars Bridge SC6462771	OUT OF SERVICE	30.21%	3	439 hrs	24/09/2019 – Engineer attended site, found top floor landing and car doors forced open. Car door belt and both landing locks broken. Engineer made safe and left off for further works. Parts ordered and engineer returned on the 30/09/2019 where parts were fitted but a new processor fault was detected. Further parts required and are on order. Lift out of service at end of reporting period.

Additional information