

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 3 public escalator/lifts that were operational for less than 95% of the time.
- The report was created on 17th December 2019 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 16/12/2019	% of time in service Between 22/11/2019 and 16/12/2019	Number of times reported Between 22/11/2019 and 16/12/2019	Period of time Not in Use Between 22/11/2019 and 16/12/2019	Comments Where the service is less than 95%
Millennium Bridge SC6459245	OUT OF SERVICE	0%	0	576 hours	Lift was out of service for the whole period, due to ongoing repairs with the energy chain. Return to service is expected week ending the 20/12/2019.
London Wall Down Escalator SC6458958	OUT OF SERVICE	0%	0	576 hours	Escalator was out of service for the whole period, due to ongoing repairs in relation to the handrail drive gear being faulty and needing to be manufactured and replaced. Return to service is expected week ending 20/12/2019.
London Wall West SC64558965	IN SERVICE	56.5%	11	252 hours	22/11/2019 – Lift was out of service due to entrapment, passengers released, and lift returned to service. Fault caused by the lift floor sensor being faulty. 30/11/2019 - Lift was out of service due to entrapment, passengers released, and lift returned to service. Fault caused by a 2 nd lift door sensor being faulty. 03/12/2019 – Engineer attended and found the primary safety circuit lost to the lift, repaired and returned to service.