


PLANNING AND TRANSPORTATION COMMITTEE REPORT 27/04/2020 – 15/05/2020



Code	Name	Time OOS	Availability
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7963	London Wall East SC6458964	0 01:12	99.74%
0978	Atlantic House SC6458966	0 09:07	98.00%
0916	Glass South Tower SC6459244	1 01:38	94.38%
7997	33 King Williams Street SC6462850	1 15:04	91.43%
7960	London Wall West SC6458965	18 21:45	0.49%
0924	Duchess Walk Public Lift LIFT CL24	18 23:59	0.00%
0929	Millennium Bridge Inclinator SC6459245	18 23:59	0.00%
0944	London Wall Down Escalator SC6458958	18 23:59	0.00%
7964	Blackfriars Bridge SC6462771	18 23:59	0.00%
0945	London Wall Up Escalator SC6458959	18 23:59	0.00%
0976	Pilgrim Street SC6458969	18 23:59	0.00%
7740	Moor House SC6458968	18 23:59	0.00%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 10- public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 19th May 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 27/04/2020 – 15/05/2020

Location	Status as of 19/05/2020	% of time in service Between 27/04/2020 and 15/05/2020	Number of times reported Between 27/04/2020 and 15/05/2020	Period of time Not in Use Between 27/04/2020 and 15/05/2020	Comments Where the service is less than 95%
Glass South Tower SC6459244	In service	94.38%	1	25 hours	Engineer attended and found debris in the tracks not allowing doors to close, return visit with specialist removal equipment followed. Lift left in service
Pilgrim Street SC6458969	Out of service	0%	0	432 hours	Lift out of service during reporting period due to project work to complete a lift Refurbishment.
Millennium Bridge Inclinor SC6459245	Out of service	0%	0	432 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.
London Wall Down Escalator SC6458958	Out of service	0%	0	432 hours	Escalator taken out of service and used as stairs due to the Up escalator being refurbished
London Wall West SC6458965	Out of service	0%	0	430 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.
Moor House SC6458968	Out of service	0%	0	432 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.
Duchess Walk SC6462323	Out of Service	0%	0	432 hours	Lift shut down due to water ingress in the lift shaft. Work underway to create a gully to divert the water away from the lift shaft.
33 King Williams Street Lift	In service	91.43%	1	39 hours	Lift lost communication link, engineer attended and repaired cable after interaction with BT.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 27/04/2020 – 15/05/2020

Blackfriars Bridge SC6462771	Out of Service	0%	0	432 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.
London Wall Up Escalator SC6458959	Out of service	0%	0	432 hours	Lift out of service during reporting period due to Project work to complete a refurbishment