


PLANNING AND TRANSPORTATION COMMITTEE REPORT 16/05/2020 – 05/06/2020



Code	Name	Time OOS	Availability
0916	Glass South Tower SC6459244	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7964	Blackfriars Bridge SC6462771	0 00:00	100%
7997	33 King Williams Street SC6462850	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
0976	Pilgrim Street SC6458969	4 00:53	80.78%
0978	Atlantic House SC6458966	5 02:38	75.67%
7345	Speed House Public Lift SC6459146	10 14:36	49.48%
0929	Millennium Bridge Inclinator SC6459245	16 22:48	21.27%
7960	London Wall West SC6458965	20 23:59	0.00%
0924	Duchess Walk Public Lift CL24	20 23:59	0.00%
0944	London Wall Down Escalator SC6458958	20 23:59	0.00%
0945	London Wall Up Escalator SC6458959	20 23:59	0.00%
0001	Moor House SC6458968	20 23:59	0.00%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 9 - public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 10th June 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 16/05/2020 – 05/06/2020

Location	Status as of 05/06/2020	% of time in service Between 16/05/2020 and 05/06/2020	Number of times reported Between 16/05/2020 and 05/06/2020	Period of time Not in Use Between 16/05/2020 and 05/06/2020	Comments Where the service is less than 95%
Atlantic House SC6458966	In service	75.67%	2	124 hours	18/05/2020 – Engineer attended site and found fault with the door, rectified and left in service 23/05/2020 – Engineer attended site and found a reoccurring fault with door; parts required and return visit completed the repair when the stock had arrived.
Pilgrim Street SC6458969	In service	80.78%	1	97 hours	Lift was brought back into service on the 20 th May 2020 after a refurbishment project was undertaken.
Millennium Bridge Inclinator SC6459245	In service	21.27%	1	384 hours	Lift was brought back into service on the 1 st June 2020 after the lock down period.
London Wall Down Escalator SC6458958	Out of service	0%	0	480 hours	Escalator taken out of service due to extensive repair project to the UP escalator and is therefore being used as stairs.
London Wall West SC6458965	Out of service	0%	0	480 hours	Lift taken out of service during reporting period due to the commencement of a short project of works, it is anticipated that the lift will be back in-service w/c 15 th June.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 16/05/2020 – 05/06/2020

Moor House SC6458968	Out of service	0%	0	480 hours	Lift out of service during reporting period due to the lock down period, fault found when returning the lift to service. Expected to be put back in service on the 10 th June.
Duchess Walk SC6462323	Out of Service	0%	0	480 hours	Lift taken out of service during reporting period due to ongoing issue with water ingress. Issue has been addressed and the lift is to be brought back into service w/c 8 th June.
Speed House Public Lift SC6459146	In service	49.48%	1	256 hours	Engineer attended and found fault with the phone line, lift taken out of service for health and safety reasons, repair with BT for resolution.
London Wall Up Escalator SC6458959	Out of Service	0%	1	480 hours	Escalator taken out of service due to extensive repair project, work expected to be completed w/c 15 th June.