


## PLANNING AND TRANSPORTATION COMMITTEE REPORT 06/06/2020 – 26/06/2020



Code	Name	Time OOS	Availability
0916	Glass South Tower SC6459244	0 00:00	100%
0945	London Wall Up Escalator SC6458959	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7997	33 King Williams Street SC6462850	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
0978	Atlantic House SC6458966	0 10:01	98.01%
0929	Millennium Bridge Inclinator SC6459245	2 01:25	90.19%
7964	Blackfriars Bridge	7 21:00	63.00%
7960	London Wall West SC6458965	10 06:12	51.15%
0944	London Wall Down Escalator SC6458958	13 07:50	36.54%
7345	Speed House Public Lift SC6459146	8 07:38	12.77%
0976	Pilgrim Street SC6459146	19 20:41	5.42%
0924	Duchess Walk Public Lift CL24	20 23:25	0.11%
7740	Moor House SC6458968	20 23:59	0.00%
7998	Tower Place Public Lift SC6458962	20 23:59	0.00%

### Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 9 - public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 26<sup>th</sup> June 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 06/06/2020 – 26/06/2020

Location	Status as of 26/06/2020	% of time in service Between 06/06/2020 and 26/06/2020	Number of times reported Between 06/06/2020 and 26/06/2020	Period of time Not in Use Between 06/06/2020 and 26/06/2020	Comments Where the service is less than 95%
Pilgrim Street SC6458969	In service	5.42%	1	455 hours	Lift has been brought back into service post a refurbishment project.
Millennium Bridge Inclinators SC6459245	In service	90.19%	1	47 hours	Lift out of service at the end of the reporting period due to vandalism to the doors. Repair is underway and expected return to service is week commencing the 29 <sup>th</sup> June 2020.
London Wall Down Escalator SC6458958	Out of service	0%	0	480 hours	Escalator out of service due to the delivery of a major project being delivered to the UP escalator, the down escalator is being used as stairs whilst this project is underway. Return to service expected week commencing the 29 <sup>th</sup> June 2020.
London Wall UP Escalator	Out of service	0%	0	480 hours	Escalator out of service due to the delivery of a major project. Return to service expected week commencing the 29 <sup>th</sup> June 2020.
London Wall West SC6458965	In service	51.15%%	1	235 hours	Lift brought back into service mid-way through reporting period following the delivery of a minor project.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 06/06/2020 – 26/06/2020

Moor House SC6458968	In service	0%	1	480 hours	Lift has had a mini project delivered during the reporting period, lift now confirmed as in service.
Duchess Walk SC6462323	In Service	52.38%	1	230 hours	Lift brought back into service following works to rectify water ingress and bi-annual engineering inspection.
Blackfriars Bridge SC6462771	In service	63%	1	180 hours	Please note that lift is switch off at night due to being vandalised, so whilst this currently takes place the lift will always show a period of being out of service.
Speed House Public Lift SC6459146	Out of Service	12.77%	1	419 hours	Lift out of service due to a failed electrical MCB switch. Issue being addressed by the highway's teams as the problem is from the Highwalk. Lift out of service at the end of the reporting period.
Tower Place Public Lift	In Service	0%	1	480 hours	Lift has had a mini project delivered during the reporting period, lift now confirmed as in service.