


## PLANNING AND TRANSPORTATION COMMITTEE REPORT 29/10/2020 – 25/11/2020



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7960	London Wall West SC6458965	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
0976	Pilgrim Street SC6458969	0 01:26	99.79%
7997	33 King Williams Street SC6462850	0 01:28	99.78%
7740	Moor House SC6458968	0 02:52	99.57%
7345	Speed House Public Lift SC6459146	0 11:23	98.31%
0978	Atlantic House SC6458966	2 04:30	92.19%
0945	London Wall Up Escalator SC6458959	2 16:39	90.38%
0929	Millennium Bridge Inclinator SC6459245	5 06:27	81.18%
0944	London Wall Down Escalator SC6458958	7 23:38	71.48%
0916	Glass South Tower SC6459244	8 16:02	69.04%
7964	Blackfriars Bridge SC6462771	27 00:00	0.00%

### Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 6 - public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 27 November 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

## PLANNING AND TRANSPORTATION COMMITTEE REPORT 29/10/2020 – 25/11/2020

Location	Status as of 25/11/2020	% of time in service Between 29/10/2020 and 25/11/2020	Number of times reported Between 29/10/2020 and 25/11/2020	Period Not in Use Between 29/10/2020 and 25/11/2020	Comments Where the service is less than 95%
Atlantic House SC6458966	Out of service	92.19%	1	<b>52 hours</b>	The lift has been taken out of service due to a modernisation project, expected return to service is 15 <sup>th</sup> February 2021.
London Wall Up Escalator SC6458969	In service	90.38%	1	<b>64 hours</b>	Escalator isolated over the weekend by possible members of the public, return to service delayed due to faulty emergency button as parts required.
Millennium Bridge Inclinator SC6459245	In service	81.18%	1	<b>124 hours</b>	Engineer attended site and found an issue with intermittent communication connection, parts required.
London Wall Down Escalator SC6458969	In service	71.48%	1	<b>188 hours</b>	Escalator isolated over the weekend by possible members of the public, return to service delayed due to faulty emergency button as parts required.
Glass South Tower SC6459244	In service	69.04%	1	<b>204 hours</b>	Engineer attended site and could not diagnose the fault; a Technical engineer visit was undertaken and identified a faulty door belt, parts required.
Blackfriars Bridge SC6462771	Out of service	0%	1	<b>658 hours</b>	The lift is out of service for the whole reporting period due to an ongoing project, expected return to service date is the 3 <sup>rd</sup> December 2020.