

## PLANNING AND TRANSPORTATION COMMITTEE REPORT

### Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. This is a report by exception, and hence, only the two listed lifts/escalators that suffered breakdown within the reporting period are shown within this report.
- The report was created on 20<sup>th</sup> September 2016 and subsequently since this time the public lifts or escalators could have been brought back into service or experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of  20/09/2016	% of time in service between 31/08/2016 and 20/09/2016	Number of times reported Between 31/08/2016 and 20/09/2016	Period of time Not in Use Between 31/08/2016 and 20/09/2016	Comments  Where the service is less than 95%
<b>London Wall (No.1) Escalator (UP) 2003 SC6458959</b>	OUT OF SERVICE	0%			This escalator is currently undergoing a refurbishment programme. Anticipated return to service date is mid-October.
<b>Wood Street Public Lift (Royex House) 2008 SC6458970</b>	OUT OF SERVICE	48.7%	1	320 hrs	06/09/2016 - Engineer attended site and found the lift running but not fully levelling with the floor. Further investigation found a blocked valve block and the hydraulic oil tank excessively hot. A hydraulic engineer has visited and found parts required which are on order.

### *Additional information*