

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. This is a report by exception, and hence, only the three listed lifts/escalators that suffered breakdown within the reporting period are shown within this report.
- The report was created on 18 November 2016 and subsequently since this time the public lifts or escalators may have been brought back into service or experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of 16/11/2016	% of time in service between 12/10/2016 and 16/11/2016	Number of times reported Between 12/10/2016 and 16/11/2016	Period of time Not in Use Between 12/10/2016 and 16/11/2016	Comments Where the service is less than 100%
London Wall (No.1) Escalator (UP)	OUT OF SERVICE	0%	0	840 hrs	Lift out of service from 09/08/2016, refurbishment of escalator gearbox and drive unit underway. Current schedule for completion is early December.
London Wall (No.1) Lift Western Pavilion	OUT OF SERVICE	78%	1	184 hrs	08/11/2016 Lift developed an electrical fault caused by the motor failing. The motor has been replaced but unfortunately another fault with the control panel was identified due to the loss of power, parts have been ordered. Estimated return to service 23 rd November 2016.
Tower Bridge Underspan	OUT OF SERVICE	0%	0	840 hrs	Lift taken out of service due to Tower Bridge Bascule re-decking project.

Additional information