

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. This is a report by exception, and hence, only the three listed lifts/escalators that suffered breakdown within the reporting period are shown within this report.
- The report was created on 30 November 2016 and subsequently since this time the public lifts or escalators may have been brought back into service or experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of 29/11/2016	% of time in service between 17/11/2016 and 29/11/2016	Number of times reported Between 17/11/2016 and 29/11/2016	Period of time Not in Use Between 17/11/2016 and 29/11/2016	Comments Where the service is less than 100%
London Wall (No.1) Escalator (UP) 2003 SC6458959	OUT OF SERVICE	0%	0	288 hrs	Lift out of service from 09/08/2016, Escalator dismantled to allow major overhaul of gearbox and drive unit. Rebuild of staircase underway at time of report. Expected return to service date is 5 th December 2016.
Tower Bridge Underspan SC6459244	OUT OF SERVICE	0%	0	288 hrs	Lift taken out of service due to Tower Bridge Bascule re-decking project. Inspection expected week commencing 5 th December 2016 to bring the lift back in service.
London Wall (No.1) Lift Western Pavilion 2003 SC6458965	OUT OF SERVICE	0%	0	288 hrs.	08/11/2016 - Lift developed an electrical fault caused by the motor failing. The motor has been replaced but unfortunately an additional fault with the control panel was identified due to the loss of power, made to order parts are being manufactured. Lift out of service at the time of writing this report.