

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. This is a report by exception, and hence, only the three listed lifts/escalators that suffered breakdown within the reporting period are shown within this report.
- The report was created on 9 January and subsequently since this time the public lifts or escalators may have been brought back into service or experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of 09/01/2017	% of time in service between 30/11/2016 and 09/01/2017	Number of times reported Between 30/11/2016 and 09/01/2017	Period of time Not in Use Between 30/11/2016 and 09/01/2017	Comments Where the service is less than 95%
Atlantic House 2001 SC6458966	IN SERVICE	87.8%	0	120 hrs	29/11/16 – Engineer attended site and found problem with the door mechanism. Parts required repair time delayed due to difficulty obtaining obsolete parts. Engineer returned to site on the 05/12/16 repaired and returned to service.
London Wall (No.1) Lift Western Pavilion 2003 SC6458965	IN SERVICE	87.8%	0	120 hrs	Lift was back in service from 5/12/16 as reported at the last meeting on the 13 December. The lift has been working fully since this time.
London Wall (No.1) Escalator (UP) 2003 SC6458959	IN SERVICE	80.5%	0	192 hrs	Escalator was back in service from 5/12/16 as reported at the last meeting on the 13 December. The lift has been working fully since this time.

Additional information