

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. This is a report by exception, and hence, only the single lift that suffered breakdown within the reporting period are shown within this report.
- The report was created on 15 February 2017 and subsequently since this time the public lifts or escalators may have been brought back into service or experienced further breakdowns which will be conveyed in the next report.

| Location And Age | Status as of 14/02/2017 | % of time in service between 25/01/2017 and 14/02/2017 | Number of times reported Between 25/01/2017 and 14/02/2017 | Period of time Not in Use Between 25/01/2017 and 14/02/2017 | Comments Where the service is less than 95% |
|-------------------------------------------|----------------------------------------|-----------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Tower Place Car Park SC6458962 | NOT IN SERVICE | 93.0% | 1 | 37 hrs | 13/02/2017 – Engineer attended site and found a fault on the telephone line. Although the lift is operational it has been taken out of service for H&S entrapment reasons. Historically BT take a long time to resolve lift phone line issues |

Additional information

Historically BT take a long time to resolve lift phone line issues despite an enhance service level for the public lifts. Despite our best efforts we anticipate Tower Place Car Park showing a significant period of “out of service” in the next lift report.