

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. The report below contains details of the one public lift that was out of service more than 95% of the time.
- The report was created on 11th July 2017 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of 11/07/2017	% of time in service between 21/06/2017 and 11/07//2017	Number of times reported Between 21/06/2017 and 11/07//2017	Period of time Not in Use Between 21/06/2017 and 11/07//2017	Comments Where the service is less than 100%
Speed House SC6459146	IN SERVICE	65.2%	9	192	<ol style="list-style-type: none">1. A problem with the autodialler meant that lift could not be in service for Health and Safety reasons, this fault was rectified within 36 hours.2. An engineer was called to site and identified that there was no power to the lift. Further investigation found the power supply to be faulty and it subsequently took 156 hours to rectify due to severity of the fault.

Additional information