

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. The report below contains details of the two public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 22nd September 2017 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of 22/09/2017	% of time in service between 12/07/2017 and 22/09/2017	Number of times reported Between 12/07/2017 and 22/09/2017	Period of time Not in Use Between 12/07/2017 and 22/09/2017	Comments Where the service is less than 95%
London Wall (No.1) Escalator (UP) 2003 SC6458959	IN SERVICE	47.9%	1	600 hrs	01.08.17- 22.08/17 - Escalator was removed from service due to broken comb plate. Whilst out of service, an unknown engineer associated with the building which the motor room is situated in switched the escalator on which caused further damage and delayed the overall repair. Access to the motor room is now restricted to City of London staff and contractors only to avoid a repeat incident.
Wood Street Public Lift 2008 SC6458970	IN SERVICE	83%	1	216hrs	16.08.17 – 24.08.17 – Engineer attended site and found the lift was not levelling correctly at the top floor. A specialist engineer was required due to the closed protocol system they attended on the 24.08.17 and corrected the fault and left in service.

Additional information