

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. The report below contains details of the two public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 17th January 2018 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of 16.01.18	% of time in service between 20.12.17 and 16.01.18	Number of times reported Between 20.12.17 and 16.01.18	Period of time Not in Use Between 20.12.17 and 16.01.18	Comments Where the service is less than 95%
Speed House SC6459146	IN SERVICE	72.1%	3	181 hrs	Lift was initially reported as out of service on the 1 st Jan'18 with the lift safety edges found to be at fault. Follow up visits were undertaken on the 3 rd and 5 th on Jan'18 to fit new parts and address further issues which had been identified before the lift could be left in service on the 5 th Jan.

Additional information