

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 14 Public Lifts/Escalators in the City of London estate. The report below contains details of the two public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 26th March 2018 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location And Age	Status as of 26.03.18	% of time in service between 07.02.18 and 26.03.18	Number of times reported Between 07.02.18 and 26.03.18	Period of time Not in Use Between 07.02.18 and 26.03.18	Comments Where the service is less than 95%
Speed House SC6459146	IN SERVICE	90.8%	2	73 hrs	03/03/18 – Fault reported which found the lift car doors stuck open, the engineer was unable to reset due to electrical fuses continually blowing. Specialist engineer attendance required, and they found a significant electrical fault with the wiring governor tension frame and landing gear control. Parts required and once received the connection was reinstated, faults cleared, lift tested and left in service.
London Wall (No.1) Lift Western Pavilion 2003 SC6458965	IN SERVICE	81.8%	1	144 hrs	06/03/2018 - Lift failed due to door operator's primary safety circuit failure which required the attendance of a specialist engineer. Fault diagnosed, and parts ordered, lift repaired, tested and left in service.

Additional information