

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 5-public escalator/lifts that were working for less than 95% of the time.
- The report was created on 10th February 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

Location	Status as of 30/01/2020	% of time in service Between 10/01/2020 and 30/01/2020	Number of times reported Between 10/01/2020 and 30/01/2020	Period of time Not in Use Between 10/01/2020 and 30/01/2020	Comments Where the service is less than 95%
London Wall West SC64558965	In Service	36.56%	1	275 hours	15/01/2019 – Engineer attended site and found top floor lock and levelling sensors faulty this has been an ongoing problem. Lift taken out of service, whilst replacement parts ordered. Once parts arrived engineer attended site and repaired, lift left in service.
33 King William St SC6462850	In Service	86.87%	1	57 hours	26/01/2020 – Engineer attended and found lift out of service due to faulty door operation. Parts ordered and engineer attended and returned to service on return visit.
London Wall Down Escalator SC6458958	In Service	65.82%	1	156 hours	Escalator out of service at beginning of reporting period, due to continuation of insurance works, works completed and Escalator returned to service on the 16/01/2020
Millennium Bridge SC6459245	In Service	85.21	1	65 hours	18/01/2020 – Engineer attended and found a faulty door landing system, parts ordered, and engineer returned on the 21/01/20 to repair and put back in service. These parts have now been added to our critical spares held at the Guildhall.

PLANNING AND TRANSPORTATION COMMITTEE REPORT

Location	Status as of 30/01/2020	% of time in service Between 10/01/2020 and 30/01/2020	Number of times reported Between 10/01/2020 and 30/01/2020	Period of time Not in Use Between 10/01/2020 and 30/01/2020	Comments Where the service is less than 95%
Blackfriars Bridge SC6462771	Out of service	21.56%	1	339 hours	16/01/2020 – Lift door damaged due to forced release by London Fire Brigade, new doors are being manufactured. Expected return to service is the 14/02/20. Lift out of service at end of reporting period.

Additional information