


PLANNING AND TRANSPORTATION COMMITTEE REPORT 07/04/2020 – 26/04/2020



Code	Name	Time OOS	Availability
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift 13 SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7998	Public Lift 1	0 00:00	100%
7999	Scenic Lift 1	0 00:00	100%
7997	33 King Williams Street Lift 1	14 07:15	28.49%
0916	Glass South Tower SC6459244	15 04:24	24.08%
0929	Millennium Bridge Inclinorator SC6459245	24 23:59	0%
0944	London Wall Down Escalator SC6458958	24 23:59	0%
7740	Moor House SC6458968	24 23:59	0%
7960	London Wall West SC6458965	24 23:59	0%
0976	Pilgrim Street SC6458969	24 23:59	0%
7964	Blackfriars Bridge SC6462771	24 23:59	0%
0945	London Wall Up Escalator SC6458959	24 23:59	0%
0924	Duchess Walk Public Lift CL24	24 23:59	0%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 10 - public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 29th April 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 07/04/2020 – 26/04/2020

Location	Status as of 07/04/2020	% of time in service Between 07/04/2020 and 26/04/2020	Number of times reported Between 07/04/2020 and 26/04/2020	Period of time Not in Use Between 07/04/2020 and 26/04/2020	Comments Where the service is less than 95%
Glass South Tower SC6459244	In service	24.08%	1	375 hours	Lift reported faulty an engineer attended, parts required and ordered. Return visit undertaken and lift repaired and left in service.
Pilgrim Street SC6458969	Out of service	0%	0	480 hours	Lift out of service during reporting period due to Project work to complete a lift refurbishment
Millennium Bridge Inclinators SC6459245	Out of service	0%	0	480 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.
London Wall Up Escalator SC6458958	Out of service	0%	0	480 hours	Lift out of service during reporting period due to Project work to complete a refurbishment
London Wall Down Escalator SC6458958	Out of service	0%	0	480 hours	Escalator taken out of service and used as stairs due to the Up escalator being refurbished.
London Wall West SC6458965	Out of service	0%	0	480 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.
Moor House SC6458968	Out of service	0%	0	480 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.
Duchess Walk SC6462323	Out of Service	0%	0	480 hours	Lift shut down due to water ingress in the lift shaft. Work underway to create a gully to divert the water away from the lift shaft.
33 King Williams Street Lift 1	In service	28.49%	1	340 hours	Lift reported faulty an engineer attended, parts required and ordered. Return visit undertaken and lift repaired and left in service.
Blackfriars Bridge SC6462771	Out of Service	0%	0	480 hours	Lift shut down on the 24 th March due to the Covid-19 Pandemic. Contractor unable to provide an emergency response for an entrapment.

