


PLANNING AND TRANSPORTATION COMMITTEE REPORT 18/09/2020 – 07/10/2020



Code	Name	Time OOS	Availability
0945	London Wall Up Escalator SC6458959	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7997	33 King Williams Street SC6462850	0 00:00	100%
0976	Pilgrim Street SC6458969	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
0924	Duchess Walk Public Lift CL24	0 02:39	99.45%
7740	Moor House SC6458968	0 16:41	96.52%
7998	Tower Place Public Lift SC6458962	0 20:22	95.76%
7960	London Wall West SC6458965	1 18:20	91.18%
0978	Atlantic House SC6458966	1 23:21	90.14%
0944	London Wall Down Escalator SC6458958	2 21:07	85.60%
7963	London Wall East SC6458964	3 18:13	81.20%
0916	Glass South Tower SC6459244	7 23:10	60.17%
0929	Millennium Bridge Inclinator SC6459245	19 07:16	3.48%
7964	Blackfriars Bridge SC6462771	19 23:59	0.00%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 7 public escalator/lifts that were in service less than 95% of the time.
- The report was created on 12 October 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 18/09/2020 – 07/10/2020

Location	Status as of 07/10/2020	% of time in service Between 18/09/2020 and 07/10/2020	Number of times reported Between 18/09/2020 and 07/10/2020	Period of time Not in Use Between 18/09/2020 and 07/10/2020	Comments Where the service is less than 95%
London Wall West SC6458965	In service	91.18%	1	416 hours	Engineer attended and could not get access to the Lift Motor Room at 1 London Wall. Return follow up visit and engineer identified that the lift electrics had tripped. Lift reset and left in service.
Atlantic House SC6458966	In service	90.14%	1	411 hours	Engineer attended and found an intermittent fault with the lift communication system, issue is ongoing, but lift is back in service.
London Wall Down Escalator SC6458958	In service	90.92%	1	414 hours	Engineer attended and found the escalator emergency stop button had been activated over a weekend. Escalator brought back into service next working day.
London Wall East SC6458964	In service	81.20%	1	373 hours	Engineer attended site and found a fault with the primary safety circuit as the lift was not communicating. Parts required, engineer returned to site when received and repair lift and left in service.
Glass South Tower SC6459244	In service	60.17%	1	275 hours	Engineer attended site and found a fault with the lift car door operation. Parts required, engineer returned to site when received and repair lift and left in service.
Millennium Bridge Inclinator SC6459245	In service	3.48%	1	440 hours	The EVAC safety system had failed, the Inclinator was back in service on the 5 th October 2020.
Blackfriars Bridge SC6462771	Out of service	74.30%%	1	160 hours	Lift out of service for the duration of the reporting period due to a failed UPS unit. Replacement has

PLANNING AND TRANSPORTATION COMMITTEE REPORT 18/09/2020 – 07/10/2020

					been approved and work is due to start on site on the 19 th October.
--	--	--	--	--	---