


## PLANNING AND TRANSPORTATION COMMITTEE REPORT 08/10/2020 – 26/10/2020



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
0929	Millennium Bridge Inclinator SC6459245	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7960	London Wall West SC6458965	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
0916	Glass South Tower SC6459244	0 09:00	98.03%
0976	Pilgrim Street SC6458969	0 12:55	97.06%
7740	Moor House SC6458968	1 14:58	91.13%
7997	33 King Williams Street SC6462850	2 04:08	88.13%
0978	Atlantic House SC6458966	2 11:16	86.51%
0944	London Wall Down Escalator SC6458958	5 11:36	71.46%
0945	London Wall Up Escalator SC6458959	7 01:19	62.86%
7964	Blackfriars Bridge SC6462771	18 23:59	0.00%

### Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 6 - public escalator/lifts that were out of service more than 95% of the time.
- The report was created on 27 October 2020 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

**PLANNING AND TRANSPORTATION COMMITTEE REPORT 08/10/2020 – 26/10/2020**

<b>Location</b>	<b>Status as of 26/10/2020</b>	<b>% of time in service Between 08/10/2020 and 26/10/2020</b>	<b>Number of times reported Between 08/10/2020 and 26/10/2020</b>	<b>Period Not in Use Between 08/10/2020 and 26/10/2020</b>	<b>Comments Where the service is less than 95%</b>
Moor House SC6458968	In service	91.13%	1	<b>40 hours</b>	Engineer attended site and found an intermittent communications fault whereby the auto dialler was functional but reporting data being lost, issue was rectified, and lift left in service.
33 King Williams Street SC6462850	In service	88.13%	1	<b>54 hours</b>	Engineer attended site and found a fault with the door track, fault rectified, and lift returned to service.
Atlantic House SC6458966	In service	86.51%	1	<b>61 hours</b>	Engineer attended site and found an intermittent communications fault whereby the auto dialler was functional but reporting data being lost, issue was rectified, and lift left in service.
London Wall Down Escalator SC6458969	In service	71.46%	3	<b>130 hours</b>	3 outages caused by the escalator emergency stop button being pressed over the weekend period.
London Wall Up Escalator SC6458969	In service	62.86%	4	<b>170 hours</b>	4 outages caused by the escalator emergency stop button being pressed over the weekend period.
Blackfriars Bridge SC6462771	Out of service	0%	1	<b>456 hours</b>	Lift out of service for the duration of the reporting period due to replacement of the failed UPS unit, lift expected to be returned to service by the 20 <sup>th</sup> November 2020.