


## PLANNING AND TRANSPORTATION COMMITTEE REPORT 12/12/2020 – 08/01/2021



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
0976	Pilgrim Street SC6458969	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7960	London Wall West SC6458965	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7740	Moor House SC6458968	0 05:57	99.11%
0929	Millennium Bridge Inclinorator SC6459245	0 19:08	97.15
7997	33 King Williams Street SC6462850	0 21:33	96.79%
0945	London Wall Up Escalator SC6458959	12 01:08	56.97%
0944	London Wall Down Escalator SC6458958	18 13:24	33.72%
0916	Glass South Tower SC6459244	19 17:15	29.57%
7964	Blackfriars Bridge SC6462771	27 14:13	0.00%

**Points to Note:**

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 4 - public escalator/lifts that were out of service for 95% or less of the time.
- The report was created on 8 January 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

**PLANNING AND TRANSPORTATION COMMITTEE REPORT 12/12/2020 – 08/01/2021**

<b>Location</b>	<b>Status as of 08/01/2021</b>	<b>% of time in service Between 12/12/2020 and 08/01/2021</b>	<b>Number of times reported Between 12/12/2020 and 08/01/2021</b>	<b>Period Not in Use Between 12/12/2020 and 08/01/2021</b>	<b>Comments Where the service is less than 95%</b>
London Wall (No.1) Escalator (UP) SC6458959	In service	56.97%	1	290 hours	Emergency Stop button pressed on escalator many times over the Christmas period, each instance was responded to within 24 hours as per the contractor agreement.
London Wall (No.1) Escalator (Down) SC6458958	Out of Service	33.72%	1	446 hours	Escalator out of service due to broken steps and step chains, the rectification works have been agreed, parts ordered with an expected return to service date of the 31 <sup>st</sup> January 2021 at the latest.
Glass South Tower SC6459244	In Service	29.57%	1	474 hours	An ongoing issue has been identified with the controls for the lift which means it is regularly not working, each time it fails an engineer attends and provides a temporary fix. A survey is being undertaken to provide details of a full-scale refurbishment project which will be brought forward to address the controls issue plus other parts of the lift which are coming to the end of their natural life.
Blackfriars Bridge SC6462771	Out of service	0%	1	672 hours	Lift out of service for the whole reporting period due to Safety Improvement Project. Lift returned to service on the 12 <sup>th</sup> January 2021.