


PLANNING AND TRANSPORTATION COMMITTEE REPORT 09/01/2021 – 29/01/2021



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
0931	Baynard House Car Park SC6458796	0 00:00	100%
0976	Pilgrim Street SC6458969	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7997	33 King Williams Street SC6462850	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7740	Moor House SC6458968	0 05:52	98.84%
7964	Blackfriars Bridge SC6462771	0 20:08	96.01%
0916	Glass South Tower SC6459244	2 00:34	90.36%
0945	London Wall Up Escalator SC6458959	2 11:02	88.29%
7960	London Wall West SC6458965	4 12:46	78.42%
0929	Millennium Bridge Inclinator SC6459245	10 02:42	51.84%
0944	London Wall Down Escalator SC6458958	17 08:12	17.42%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 5 - public escalator/lifts that were not available for 95% of the time or less.
- The report was created on 29th January 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 09/01/2021 – 29/01/2021

Location	Status as of 29/01/2021	% of time in service Between 09/01/2021 and 29/01/2021	Number of times reported Between 09/01/2021 and 29/01/2021	Period Not in Use Between 09/01/2021 and 29/01/2021	Comments Where the service is less than 95%
London Wall (No.1) Escalator (UP) SC6458959	In service	88.29%	1	51 hours	The escalator was taken out of service when the down escalator was undergoing the major repairs to allow for a two-way stair access to be provided.
London Wall (No.1) Escalator (Down) SC6458958	In Service	17.42%	1	357 hours	The escalator has been out of service since the last reporting period due to a step and chain repair. Works to the escalated were completed on the 27 th January 2021.
Glass South Tower SC6459244	In Service	90.36%	1	42 hours	There are ongoing recurrent minor faults, a survey has been undertaken to identify the fault to ensure that it is repaired correctly in the line with their recommendations.
London Wall West SC6458965	In Service	78.42%	1	93 hours	Fault found with the door safety edges which required parts. Once received the engineer returned to site and put the lift back in service.
Millennium Bridge Inclinor SC6459245	Out of service	51.84%	1	208 hours	Engineer attended and found a fault with the control panel caused by vandalism, parts required and currently out of service whilst these are received and fitted. Expected to be returned to service week commencing the 8 th February 2021.