


## PLANNING AND TRANSPORTATION COMMITTEE REPORT 20/02/2021 – 12/03/2021



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
0945	London Wall Up Escalator SC6458959	0 00:00	100%
0976	Pilgrim Street SC6458969	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7960	London Wall West SC6458965	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7964	Blackfriars Bridge SC6462771	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7740	Moor House SC6458968	0 05:09	98.98%
0944	London Wall Down Escalator SC6458958	1 22:23	90.80%
7730	Wood Street Public Lift SC6458970	2 01:55	90.10%
7997	33 King Williams Street SC6462850	2 20:14	86.46%
0916	Glass South Tower SC6459244	6 19:27	67.57%
0929	Millennium Bridge Inclinator SC6459245	19 01:32	9.22%

### Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 5 - public escalator/lifts that were out of service for less than 95% of the time.
- The report was created on 16 March 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

**PLANNING AND TRANSPORTATION COMMITTEE REPORT 20/02/2021 – 12/03/2021**

<b>Location</b>	<b>Status as of 16/03/2021</b>	<b>% of time in service Between 20/02/2021 and 16/03/2021</b>	<b>Number of times reported Between 20/02/2021 and 16/03/2021</b>	<b>Period Not in Use Between 20/02/2021 and 16/03/2021</b>	<b>Comments Where the service is less than 95%</b>
London Wall (No.1) Escalator (Down) SC6458958	In service	90.80.%	1	44 hours	Escalator turned off by several members of the public on repeated occasions. This is an amalgamation of the time out of service.
Wood Street Public Lift SC6458970	In Service	90.10%	1	47 hours	Engineer attended site and found a mechanical failure, parts required. Engineer returned when received, repaired and left the lift in service.
33 King Williams Street SC6462850	In Service	86.46%	1	65 hours	Engineer attended site and found a mechanical failure, parts required. Engineer returned when received, repaired and left the lift in service.
Glass South Tower SC6459244	Out of Service	67.57%	1	156 hours	Engineer attended site and found a fault with the drive mechanism; replacement parts are on order and we are currently waiting for delivery. Lift remains out of service.
Millennium Bridge Inclinator SC6459245	In Service	9.2%	1	436 hours	Inclinator repaired and returned to service on the 11 <sup>th</sup> March 2021.