


PLANNING AND TRANSPORTATION COMMITTEE REPORT 07/04/2021 – 26/04/2021



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
0976	Pilgrim Street SC6458969	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7964	Blackfriars Bridge SC6462771	0 00:00	100%
7997	33 King Williams Street SC6462850	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 01:12	99.75%
0916	Glass South Tower SC6459244	0 07:24	98.46%
7740	Moor House SC6458968	0 07:45	98.39%
0945	London Wall Up Escalator SC6458959	2 10:05	87.90%
0944	London Wall Down Escalator SC6458958	3 01:27	84.70%
0929	Millennium Bridge Inclinator SC6459245	10 07:20	48.47%
7960	London Wall West SC6458965	19 23:28	0.11%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 4 - public escalator/lifts that were out of service for less than 95% of the time.
- The report was created on 28 April 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 07/04/2021 – 26/04/2021

Location	Status as of 26/04/2021	% of time in service Between 07/04/2021 and 26/04/2021	Number of times reported Between 07/04/2021 and 26/04/2021	Period Not in Use Between 07/04/2021 and 26/04/2021	Comments Where the service is less than 95%
London Wall (No.1) Escalator (Down) SC6458958	In service	84.70.%	2	73 hours	Unfortunately, the service was suspended by members of the public pushing the emergency stop button. We continue to work with our supplier to develop better controls to stop this from happening whilst keeping the health and safety measures in place.
London Wall (No.1) Escalator (Up) SC6458959	In service	87.90%	1	58 hours	Unfortunately, the service was suspended by members of the public pushing the emergency stop button. We continue to work with our supplier to develop better controls to stop this from happening whilst keeping the health and safety measures in place.
London Wall (No.1) Lift Western Pavilion SC6458965	In service	0.11%	1	479 hours	Lift out of service due to an issue with the communication system, parts required and lift return to service when they arrived with the engineers.
Millennium Bridge Inclinor SC6459245	In Service	48.47%	1	247 hours	Engineer attended and found damaged safety edges which prevent the doors opening and closing correctly. Replacements parts sourced and lift returned to service once they arrived with the engineers.