


PLANNING AND TRANSPORTATION COMMITTEE REPORT 27/04/2021 – 21/05/2021



Code	Name	Time OOS	Availability
0931	Baynard House Car Park SC6458796	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7960	London Wall West SC6458965	24 23:59	100%
7964	Blackfriars Bridge SC6462771	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
0944	London Wall Down Escalator SC6458958	1 07:26	100%
0924	Duchess Walk Public Lift CL24	0 02:54	99.52%
0945	London Wall Up Escalator SC6458959	0 03:32	99.41%
7997	33 King Williams Street SC6462850	0 06:06	98.98%
7740	Moor House SC6458968	0 07:28	98.76%
0929	Millennium Bridge Inclinators SC6459245	0 09:20	98.44%
0916	Glass South Tower SC6459244	0 13:55	97.68%
0976	Pilgrim Street SC6458969	12 16:50	49.19%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 1 - public escalators/lifts that has been out of service for less than 95% of the time.
- The report was created on 25 May 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 27/04/2021 – 21/05/2021

Location	Status as of 21/05/2021	% of time in service Between 27/04/2021 and 21/05/2021	Number of times reported Between 27/04/2021 and 21/05/2021	Period of time Not in Use Between 27/04/2021 and 21/05/2021	Comments Where the service is less than 95%
Pilgrim Street	Out of service	49.19.%	1	260 hours	Engineer attended and found a fault with the auto-dialler, a replacement has been ordered and the engineer is booked to attend week commencing the 24 th May 2021 when the part is due to arrive. Once the repair is complete the lift will be returned to service.