


PLANNING AND TRANSPORTATION COMMITTEE REPORT 29/12/2021 – 07/02/2021



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
0976	Pilgrim Street SC6458969	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7740	Moor House SC6458968	0 01:39	99.83%
7963	London Wall East SC6458964	0 17:32	98.22%
7964	Blackfriars Bridge SC6462771	4 13:47	88.84%
7997	33 King Williams Street SC6462850	6 13:14	84.02%
0916	Glass South Tower SC6459244	13 11:40	67.11%
0945	London Wall Up Escalator SC6458959	14 03:24	65.51%
7960	London Wall West SC6458965	20 01:21	51.08
0944	London Wall Down Escalator SC6458958	40 23:59	0.00%

Points to Note:

- There are 16 Public Lifts/Escalators in the City of London estate. The report below contains details of the 6- public escalators/lifts that was out of service more than 95% of the time.
- The report was created on 30 November 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 29/12/2021 – 07/02/2021

Location	Status as of 29/12/2021	% of time in service Between 29/12/2021 and 07/02/2022	Number of times reported Between 29/12/2021 and 07/02/2022	Period of time Not in Use Between 29/12/2021 and 07/02/2022	Comments Where the service is less than 95%
Blackfriars Bridge SC6462771	In Service	88.84%	1	110 hours	Danfoss unit failure, new unit ordered and installed
33 King Williams Street SC6462850	In Service	84.02%	1	157 hours	Drive system fault, new parts ordered and installed
Glass South Tower SC6459244	In Service	67.11%	1	324 hours	Door safety system failed which had a number of problems. New motor installed, doors repaired, debris blocking landing mechanism needed clearing.
London Wall Up Escalator SC6458959	In Service	65.51%	3	339 hours	Several shut offs by public.
London Wall West SC6458965	In Service	51.08%	1	481 hours	Auto dialler failure – new GSM unit ordered, approved and installed. Unusually slow parts delivery
London Wall Down Escalator SC6458958	Out of service	0%	0	984 hours	Specialist repair works are required and in progress. Unit requires an insurance inspection before it can be put back in service and this is booked in for 23/2/22.