


PLANNING AND TRANSPORTATION COMMITTEE REPORT 08/02/2022 – 10/04/2022



Code	Name	Time OOS	Availability
0976	Pilgrim Street SC6458969	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
0916	Glass South Tower SC6459244	0 01:15	99.92%
7963	London Wall East SC6458964	0 19:03	98.72%
0924	Duchess Walk Public Lift LIFT CL24	1 07:17	97.90%
7997	33 King Williams Street SC6462850	1 12:20	97.56%
7345	Speed House Public Lift SC6459146	2 05:42	96.39%
7740	Moor House SC6458968	2 08:45	96.18%
7964	Blackfriars Bridge SC6462771	3 07:12	94.67%
0978	Atlantic House SC6458966	5 07:08	91.45%
0945	London Wall Up Escalator SC6458959	6 08:39	89.73%
0944	London Wall Down Escalator SC6458958	30 16:33	50.47%
7960	London Wall West SC6458965	43 03:02	30.39%

Points to Note:

- There are 16 Public Lifts/Escalators in the City of London estate. The report below contains details of the 5- public escalators/lifts that was out of service more than 95% of the time.
- The report was created on 30 November 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 08/02/2022 – 10/04/2022

Location	Status as of 08/02/2022	% of time in service Between 08/02/2022 and 10/04/2022	Number of times reported Between 08/02/2022 and 10/04/2022	Period of time Not in Use Between 08/02/2022 and 10/04/2022	Comments Where the service is less than 95%
Blackfriars Bridge SC6462771	In Service	94.67%	3	79 hours	Lift has been working intermittently the past few months due to on-going reliability issues
Atlantic House SC6458966	In Service	91.45%	1	125 hours	Lift monitoring system failed. New power meter installed.
London Wall Up Escalator SC6458959	In Service	89.73%	4	151 hours	Occasional shut-downs due to persons unknown pressing emergency shut-off. Also taken out of service whilst surrounding glazing was deep cleaned.
London Wall West SC6458965	Out of Service	30.39%	5	1020 hours	Repeated problems with passengers being trapped so lift taken out of service. Primary safety circuits had failed, and various parts replaced including new shoes which were made to order and new processor which required Controls manufacturer to install them. Lift not returned to service for some time, hence extended period off-line.
London Wall Down Escalator SC6458958	In Service	50.47%	1	726 hours	Major repairs to the handrails left the escalator out of service for some time. The new installations created additional mechanical problems and repeated failures. All now resolved and currently back in service.