


PLANNING AND TRANSPORTATION COMMITTEE REPORT 12/04/2022 – 01/05/2022



Code	Name	Time OOS	Availability
0976	Pilgrim Street SC6458969	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7740	Moor House SC6458968	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
0944	London Wall Down Escalator SC6458958	0 03:21	99.30%
0916	Glass South Tower SC6459244	0 04:54	98.98%
7997	33 King Williams Street SC6462850	0 09:53	97.94%
0945	London Wall Up Escalator SC6458959	0 16:49	96.50%
7964	Blackfriars Bridge SC6462771	6 21:47	65.46%
0924	Duchess Walk Public Lift CL24	9 01:09	54.76%
7960	London Wall West SC6458965	9 09:35	53.00%

Points to Note:

- There are 16 Public Lifts/Escalators in the City of London estate. The report below contains details of the 3 - public escalators/lifts that was out of service more than 95% of the time.
- The report was created on 30 November 2021 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 12/04/2022 – 01/05/2022

Location	Status as of 12/04/2022	% of time in service Between 12/04/2022 and 01/05/2022	Number of times reported Between 12/04/2022 and 01/05/2022	Period of time Not in Use Between 12/04/2022 and 01/05/2022	Comments Where the service is less than 95%
Blackfriars Bridge SC6462771	In Service	65.46%	1	158 hours	AML Engineer attended to repair fault 18th April. The lift was restored on 21st April 2022. However, the lift was continuously going out of service when the doors are wedged open by members of the public. Now in service.
Duchess Walk SC6462323	Out of Service	54.76%	1	206 hours	Ground works started 25/4/22 in front of Duchess walk lift entrance and expected to take two weeks to complete, giving a target completion date of 9/5/22. Currently out of service.
London Wall West SC6458965	In Service	53.00%	1	214 hours	Car door safety edges were fitted 13/4/22, but door drive/motor encoder was then found to be faulty. AML sourced parts, now back in service.