


PLANNING AND TRANSPORTATION COMMITTEE REPORT 02/05/2022 – 22/05/2022



Code	Name	Time OOS	Availability
0916	Glass South Tower SC6459244	0 00:00	100%
0945	London Wall Up Escalator SC6458959	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7740	Moor House SC6458968	0 03:57	99%
7997	33 King Williams Street SC6462850	1 18:30	91.57%
0944	London Wall Down Escalator SC6458958	2 13:27	86.95%
7960	London Wall West SC6458965	2 17:47	86.64%
7964	Blackfriars Bridge SC6462771	3 03:37	85.00%
7921	Little Britain SC6458967	5 10:34	74.09%
0976	Pilgrim Street SC6458969	8 03:01	61.30%
0924	Duchess Walk Public Lift CL24	13 00:40	37.96%

Points to Note:

- There are 16 Public Lifts/Escalators in the City of London estate. The report below contains details of the 7 - public escalators/lifts that were available less than 95% of the time.
- The report was created on 24 May 2022 and subsequently since this time, the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 02/05/2022 – 22/05/2022

Location	Status as of 02/05/2022	% of time in service Between 02/05/2022 and 22/05/2022	Number of times reported Between 02/05/2022 and 22/05/2022	Period of time Not in Use Between 02/05/2022 and 22/05/2022	Comments Where the service is less than 95%
33 King Williams Street SC6462850	In Service	91.57%	3	41 hours	Communication failures, lift now back in service.
London Wall West SC6458965	In Service	86.95%	1	63 hours	Escalator failure, engineer attended site and reset escalator. Left lift in service
London Wall Down Escalator SC6458958	In Service	86.64%	1	63 hours	Failure over weekend not resolved until following Monday. Escalator in service.
Blackfriars Bridge SC6462771	In Service	85.00%	3	72 hours	The lift has been going out of service intermittently during this period. Lift currently in service.
Little Britain SC6458967	Out of service	74.09%	1	125 hours	Autodial SIM card not working, and source of problems has been unclear, so taken out of service due to non-compliance with emergency requirements. FM active with resolving the SIM issue. Lift Currently out of service
Pilgrim Street SC6458969	Out of service	61.30%	1	186 hours	Defective door opening system required bespoke replacement parts, which are due in 25/5 for installation. Lift currently out of service.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 02/05/2022 – 22/05/2022

Duchess Walk SC6462323	In Service	37.96%	1	298 hours	Major works by PPG took place over 2 weeks to drain the front side of the lift where persistent flooding and damage had occurred. Ground works needing rebuilding. Now complete and lift returned to service.
---------------------------	------------	--------	---	-----------	---