


PLANNING AND TRANSPORTATION COMMITTEE REPORT 23/05/2022 – 15/06/2022



Code	Name	Time OOS	Availability
0916	Glass South Tower SC6459244	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7740	Moor House SC6458968	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
0944	London Wall Down Escalator SC6458958	0 03:36	99.37%
0924	Duchess Walk Public Lift CL24	0 09:44	98.31%
0978	Atlantic House SC6458966	0 20:38	96.42%
7345	Speed House Glass/Public Lift SC6459146	1 11:18	93.87%
7960	London Wall West SC6458965	1 15:39	93.12%
0945	London Wall Up Escalator SC6458959	1 21:10	92.16%
7998	Tower Place Public Lift SC6458962	3 06:25	86.39%
7964	Blackfriars Bridge SC6462771	4 00:52	83.18%
	1 London Wall Lift 1	5 02:59	78.65%
7997	33 King Williams Street SC6462850	5 07:26	77.88%
7921	Little Britain SC6458967	9 09:24	60.87%
0976	Pilgrim Street SC6458969	15 11:54	35.43%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 9 - public escalators/lifts that was available less than 95% of the time.
- The report was created on 20 June 2022 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 23/05/2022 – 15/06/2022

Location	Status as of 23/05/2022	% of time in service Between 23/05/2022 and 15/06/2022	Number of times reported Between 23/05/2022 and 15/06/2022	Period of time Not in Use Between 23/05/2022 and 15/06/2022	Comments Where the service is less than 95%
Speed House Glass/Public Lift SC6459146	In Service	93.87%	1	34 hours	Lift went out of service on 8th June due to a fault with the auto dialler system. New SIM card needed to be sourced. New SIM installed on 8th June 2022 and the lift was restored to service.
London Wall West SC6458965	In Service	93.12%	1	38 hours	Lift went out of service on 22 May due to a fault with the landing doors. Engineer attended site on 23 May to correct the fault. Lift now back in service
London Wall Up Escalator SC6458959	In Service	92.16%	1	43 hours	Failure over weekend not resolved until following Monday. Escalator in service.
Tower Place Public Lift SC6458962	In Service	86.39%	1	76 hours	Lift was taken out of service on 31 May to enable Thames Valley Control to install a real time monitoring unit. The lift was put back into service on 1 June.
Blackfriars Bridge SC6462771	In Service	83.18%	3	93 hours	Lift was constantly in and out of service during this period. The lift went out of service on 30th May. AML engineer attended site to try and resolved the problem with the lift doors. Technical engineer attended on 31 May and rectified the fault. lift was restored to service.

PLANNING AND TRANSPORTATION COMMITTEE REPORT 23/05/2022 – 15/06/2022

1 London Wall Lift 1	Out of service	78.65%	1	118 hours	Lift went out of service over the weekend of 28th May, as the doors were not levelling on the ground floor. Engineer attended and adjusted floor-levelling at the start of the next week and put it back in service.
33 King Williams Street SC6462850	In Service	77.88%	1	123 hours	Lift went out of service over the weekend of 28th May, due to doors stuck open. Engineer attended to reset door mechanism at the start of the next week and put it back in service.
Little Britain SC6458967	In Service	60.87%	1	217 hours	Lift was switched off on 22 May due to inoperative auto dialler system. New SIM card was required and ordered through TVC, but confusion over disused phone connection and old number delayed resolution. Now back in service.
Pilgrim Street SC6458969	In Service	35.43%	1	356 hours	Lift went out of service due to failure of the door mechanism, which is not a standard design. Amalgamated Lifts provided incompatible parts on two occasions. Service failures raised with AML management. Correct fitting installed on 7th June 2022 and back in service.