


PLANNING AND TRANSPORTATION COMMITTEE REPORT 16/06/2022 – 03/07/2022

Availability



Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
0945	London Wall Up Escalator SC6458959	0 00:00	100%
0976	Pilgrim Street SC6458969	0 00:00	100%
0978	Atlantic House SC6458966	0 00:00	100%
7345	Speed House Glass/Public Lift SC6459146	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7740	Moor House SC6458968	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7964	Blackfriars Bridge SC6462771	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
	1 London Wall Lift 1	0 00:00	100%
7960	London Wall West SC6458965	0 09:08	97.89%
0944	London Wall Down Escalator SC6458958	0 19:52	95.40%
7997	33 King Williams Street SC6462850	0 21:27	95.03%
0916	Glass South Tower SC6459244	2 17:02	84.95%

Points to Note:

- There are 17 Public Lifts/Escalators in the City of London estate. The report below contains details of the 1 - public escalators/lifts that was available less than 95% of the time.
- The report was created on 05 July 2022 and subsequently since this time the public lifts or escalators may have experienced further breakdowns which will be conveyed in the next report.

**PLANNING AND TRANSPORTATION COMMITTEE REPORT 16/06/2022 – 03/07/2022**

<b>Location</b>	<b>Status as of 16/06/2022</b>	<b>% of time in service Between 16/06/2022 and 03/07/2022</b>	<b>Number of times reported Between 16/06/2022 and 03/07/2022</b>	<b>Period of time Not in Use Between 16/06/2022 and 03/07/2022</b>	<b>Comments Where the service is less than 95%</b>
Glass South Tower SC6459244	In Service	84.95%	1	65 hours	Job logged on Saturday 2 July 2022. Lift over travelled on top floor, reported as potential contactor failure. Lift Returned to service Monday 4 <sup>th</sup> July.