


# Planning and Transportation Committee Report – September 2022

## Reporting Period: 05/09/2022 – 25/09/2022

The public lifts and escalators listed in this report, are those which are owned and maintained by the Corporation, specifically by the City Surveyors’ department. This list excludes any public access lifts or escalators owned by the Corporation that are leased to others. City Surveyors are currently working to identify if there are any further public lifts/escalators leased to others, in addition to 125 London Wall, and what enforcement rights are at our disposal should they become unavailable.

**Fig 1.0**



**Table 1.0**

Code	Name	Time OOS	Availability
0924	Duchess Walk Public Lift CL24	0 00:00	100%
7730	Wood Street Public Lift SC6458970	0 00:00	100%
7921	Little Britain SC6458967	0 00:00	100%
7963	London Wall East SC6458964	0 00:00	100%
7998	Tower Place Public Lift SC6458962	0 00:00	100%
7999	Tower Place Scenic Lift SC6458963	0 00:00	100%
7997	33 King Williams Street SC6462850	0 03:12	99.37%
7740	Moor House SC6458968	0 03:21	99.34%
0945	London Wall Up Escalator SC6458959	0 05:57	98.82%
0916	Glass South Tower SC6459244	0 14:58	97.03%
0978	Atlantic House SC6458966	0 15:09	96.99%
0944	London Wall Down Escalator SC6458958	3 00:24	85.63%
7964	Blackfriars Bridge SC6462771	4 09:44	79.02%
0976	Pilgrim Street SC6458969	5 18:35	72.50%
7345	Speed House Glass/Public Lift SC6459146	7 20:39	62.57%
7960	London Wall West SC6458965	17 08:49	17.30%

**Points to Note:**

- There are 16 public lifts/escalators in the City of London estate, which are maintained by City Surveyors. Table 1.2 contains details of the 5 public escalators/lifts that were available for less than 95% of the reporting period
- This report was created on 27 September 2022. The public lifts or escalators may have experienced further breakdowns since this date and will be reported in the next reporting period

Planning and Transportation Committee Report – September 2022  
Reporting Period: 05/09/2022 – 25/09/2022

Table 2.0

	Status as of 05/09/2022	% of time in service Between 05/09/2022 and 25/09/2022	Number of times reported Between 05/09/2022 and 25/09/2022	Period of time Not in Use Between 05/09/2022 and 25/09/2022	Comments Where the service is less than 95%
London Wall Down Escalator SC6458958	In Service	85.63%	1	71 hours	The escalator went out of service on 9th September. It was put back into service on 12 <sup>th</sup> September. This outage was caused by the stop button being pushed by a member of the public.
Blackfriars Bridge SC6462771	In Service	79.02%	1	101 hours	Lift went out service on 13th September due to a fault with the landing doors. On inspection a large crack was evident, caused by suspected vandalism. The glass was replaced and was put back into service on 17th September.
Pilgrim Street SC6458969	In Service	72.50%	4	131 hours	Recurrent faults occurred with the auto-dialler system, which was switched off and replaced.
Speed House Glass/Public Lift SC6459146	In Service	62.57%	1	180 hours	Faults with the brakes and landing button meant it was taken out of service. Parts sourced and replaced and is now back in service.
London Wall West SC6458965	In Service	17.30%	1	397 hours	Lift out of service since 29 <sup>th</sup> August. The cause is a fault with an interface board linking hydraulic power unit to the lift controller. There have been problems fixing the equipment or sourcing a quick replacement due to supply chain problems. CoL Lifts engineers meeting with Amalgamated Lifts on 27 <sup>th</sup> September to review options.