

## Appendix 6

Message sent by Team Energy M&T Support to Site Contacts

Fri 10/03/2023 13:38

Good afternoon all,

Following our call on Tuesday, please see attached a list of meters with ASC recommendations. This list is based on the original CoL estate, filtered down to BEO properties and then to those with recommendations based on half-hourly consumption data that has been categorised as 'always dialled' by the data collector Stark (e.g. they have been able to successfully remotely read the meter for at least the last 14 months with no/minimal estimated data according to the Stark website). The recommendations can be summarised as below:

MPAN	Site name	Max (Monthly) Demand 2019 - 2022 (kVA)	Current ASC (kVA)	Recommended ASC (kVA)	TEAM Recommendation
1200020487875	Brandon Mews Barbican	223	101	278	Request new ASC
1200010107720	Bunyan Court	36	40	40	No change
1200010107855	Gilbert House S/W Rm Flat 110	26	70	33	Change ASC
1200020487990	John Trundle Court Barbican 2	494*	101	618	Change ASC
1200020488043	Mountjoy House Barbican 1	464	101	580	Change ASC
1200010107907	Mountjoy House Barbican 2	21	40	26	Change ASC
1200010107794	South Garchey Postern Wallside	67	80	84	No change